

10 AUG 1971

25X1A9a

MOVEABLE SHELVING PROJECT OBSERVATIONS AS OF 8-6-71

1. Bay 1, Center Aisle -- Plastic dust barrier pulled loose.
2. Bay 1, Sect. 2 -- Clutches need to have more shot loaded in now that boxes are on the shelves.
3. Bay 1, Sect. 1, Aisle 6, Plastic Safety Housing broken.
4. Bay 1, Sect. 1 & 2, Aisle 6, Stationary -- Secondary Safety Housing hits shelf and breaks connection apparently because bumper blocks are not long enough.
5. Bay 1, Sect. 1 -- Motor covers do not cover opening completely.
6. Bay 1 & 2, Sect. 2 & 4 -- Mosler alarm boxes hidden behind stationary.
7. Bay 1, Sect. 1, Aisle 1, Stationary -- Not room for boxes because of wires. In fact, there is a serious design problem on all equipment and wires on top shelf for all of Bay 1 that will have to be resolved before work continues on next bays: arm extender placement, excess wire in way of boxes and wires over edge of sharp metal.
8. Bay 1, Sect. 1 & 2 -- Light switch conduit warm -- Why?
9. Bay 2, Sect. 3 -- Anti-tipping device installed at least 2" from edge of shelves. It should be right on end of shelves except back 1" on end panel end.
10. Center aisle -- Ramp at door not poured.
11. Bay 3, Sect. 6 -- Fire pump conduit needs moving.
12. Bay 2, Sect. 4 -- Fire hose pipe and rack needs work.

25X1A9a

25X1A9a

C/Using Service

Distribution:

3 -  
1 -  
1 -  
1 -  
1 -  
1 -  
1 -  
1 -